



PROVIDENCE FIRE DEPARTMENT  
 FIRE PREVENTION BUREAU  
 325 Washington Street Providence, RI 02903  
 (401) 243-6050

Certificate Number	
<b>No</b>	<b>5510</b>

**Certificate for Smoke & Carbon Monoxide Alarms in Residential Occupancies**

*This certificate does not address building fire alarm systems, where required in mixed occupancy or apartment buildings (4+ units). This certificate is for proper installation and testing within residential units only.*

20 Langham RD

Address: \_\_\_\_\_  
 Unit # (if applicable): 1

Building Type: 1 Family X 2 Family \_\_\_\_\_ 3 Family \_\_\_\_\_  
 Mixed Use \_\_\_\_\_ Apartment (4 + units) \_\_\_\_\_

If fire alarm present  
 U.T.R. date: \_\_\_\_\_  
 Master Box #: \_\_\_\_\_

**TESTING AND PLACEMENT INFORMATION**

Pre-1976 Battery Operated Smokes X Carbon Monoxide—Battery X  
 Post 1976 Hardwired Smokes \_\_\_\_\_ Hardwired \_\_\_\_\_  
 Wireless Smoke Alarm Sys. Smokes \_\_\_\_\_  
 (must have certificate dated within 14 days, if monitored by a residential alarm company)

On this (date) 6/7/2014, I, Ariel Espinal,  
 Inspector for the City of Providence, inspected the Smoke and Carbon Monoxide Alarms. The units inspected were in good working order and in compliance with the R.I. Life Safety Code, 2012 ed., as amended, Chapter (Add) 24.6.3 for existing 1 or 2 family homes, or apartments in mixed use buildings; or RILSC Chapter (Add) 25.2 for existing 3 family homes; or Chapter (Add) 31.1.1.5 (2) for apartment buildings, as applies to type checked above.

It is the responsibility of the owner to maintain, in operable condition, smoke & carbon monoxide alarms, and they must be made operable within 7 days after being notified by certified mail of an inoperable system.

**PAYMENT INFORMATION**  
 Name on Check: Chris Healy  
 Check #: 23119348184

**Certificate Good for 120 days**  
 per RIFSC (Add) 24.6.3.1.4

Payment is by money order or business check (no personal check). made payable to Providence Fire Department